

ADDENDUM NO. 6

DATE: July 29, 2010
TO: PROSPECTIVE BIDDERS
PROJECT: **BOSTON CONVENTION & EXHIBITION CENTER
MARQUEE & VIDEO WALL PROJECT**

This Addendum forms part of and modifies Bidding and Contract Documents dated June 30, 2010. Acknowledge receipt of this Addendum in writing in the space provided on BID FORMS.

Where any original item called for in the Project Manual or indicated on the Drawings is supplemented hereby, the supplemental requirements shall be considered as added thereto.

Where any original item is amended, voided, or superseded hereby, the other provisions of such items not specifically amended, voided, or superseded shall remain in effect.

Questions and Answers:

Q1. Detail 8 / S132 light fixture support calls for the ¼" x 4" wide plate and the grating to be by the misc metals sub-bid, but when referenced with E303 it calls for this work to be by the GC. Please confirm who owns this scope of work, the misc metals filed sub bid or the GC?

A1. *This is part of the misc metals filed sub bid.*

Q2. Detail 2/E303 calls for the W6 x 8.5 structural steel to be by the GC, but there is also a note that calls for this to be by the misc metals filed sub-bid. When referenced with the S drawings it is called out to be by the misc. metals filed sub- bid, please confirm that this work is part of the misc. metals filed sub-bid.

A2. *This is part of the misc metals filed sub bid.*

Q3. Elevation 1/S109 shows a HSS 12 x 12 x 3/8 at Bottom of Architectural Ceiling 20'-0" but if you reference 2/S104 it shows an HSS 12 x 12 x ½. Which size is correct?

A3. *HSS 12 x 12 x ½ is correct.*

Q4. Elevation 1/S109 shows an HSS 4 x 4 x ¼ at Outrigger 34 project elevation 60'-7", but when referenced with S107 it shows an HSS 6 x 4 x 1/4. Which size is correct?

A4. *HSS 6 x 4 x 1/4 is correct.*

Q5. Addendum #3 question 3 refers to ASK-13, but we are not in receipt of ASK-13. Can you please resend this sketch?

A5. *Reference to ASK-13 should have read ASK-1 issued with Addendum No. 2. Please refer to Addendum No. 2 Sketch ASK-1.*

Q6. What is the design intent of the pipe staging / shoring shown on P101. The sections say to refer to Structural drawings for details, but there is nothing shown on the structural drawings. Please advise.

A6. *The design intent is to temporarily shore the existing pipes while the pipe hanger supports are moved and new hanger supports installed (scope shown on S101). The staging is to be designed by the General Contractor.*